



west virginia department of environmental protection

Environmental Enforcement
Tanks Program
601 57th Street SE
Charleston, WV 25304
Telephone: 304-926-0470; Fax: 304-926-0452

Harold Ward, Cabinet Secretary
www.dep.wv.gov

1/28/2026

Dear CATALYST REFINERS, INC.:

A Compliance Monitoring Inspection (CMI) was conducted at Catalyst Refiners, 15801 First Avenue South, Nitro, WV 25143 on 1/21/2026. No deficiencies were noted during the inspection of your facility. You and your staff are to be commended for your commitment to proper operation and maintenance of your facility. The following tanks were inspected:

Tank #	Capacity	Substance
020-00002536	6000	Nitric acid

Technical results below:

Category	Result
Corrosion Protection	Passed
Leak Detection	Passed
Financial Responsibility	Passed
Secondary Containment	Passed
Public Water Notified	Passed

If you have any questions, please contact Tanks inspector, GRIFFIN, JOSHUA at 304-926-0499 or Joshua.J.Griffin@wv.gov.

Sincerely,

MOLES, RICHARD I
Tanks Supervisor

cc: Charleston File
GRIFFIN, JOSHUA, Tanks Inspector at Joshua.J.Griffin@wv.gov



AST Compliance Inspection WV DEP Tanks Program

Printed: 1/21/2026 10:54 AM
Attendees: GRIFFIN, JOSHUA
Inspection Result: Passed

Inspection Date: 1/21/2026
Partial Inspection: No

Facility Name	Catalyst Refiners	Inspector	GRIFFIN, JOSHUA
Facility Address	15801 First Avenue South Nitro, WV 25143 Kanawha	Insp. Type	Compliance
		Notification Required	No

CONTACTS

Contact Type	Contact Information
Tank Owner	CATALYST REFINERS, INC., 21 Roger Street, Glens Falls, NY 12801, Phone: (518) 792-5808

INSPECTOR COMMENTS

TANKS	020-00002536
Owner Assigned ID	1
Ref #	2014-0015023
Tank Construction Material	Stainless Steel
Containment Type	Dike
Containment Material	Concrete
CP Type	Isolated
ZCC	No
ZPC	No
WPA	No
Tank Level	Level 1

COMPARTMENTS	020-00002536(1)
Owner assigned Id	1
Compartment status	Currently in use
Capacity	6000
Product(s)	Nitric acid
Pipe containment	Single Walled

COMPLIANCE RESULTS	020-00002536
All applicable fees paid	Pass
Public water notified	Pass
Financial responsibility	Pass
Fit for service	Pass
Spill plan approved	Pass
Properly registered	Pass
Proper signage displayed	Pass
Ancillary equipment	Pass
Venting	Pass
Corrosion protection	Pass

COMPLIANCE RESULTS	020-00002536
Spill / overfill	Pass
Leak detection	Pass
Secondary containment	Pass
Monthly inspection records	Pass
Internal inspection	Pass

SITE DIAGRAM**ISSUES**

In order prevent further enforcement, the issues below should be resolved as soon as possible.

No violations found in this category.

PHOTOS

Inspection performed by:



GRIFFIN, JOSHUA
WV DEP Tank Inspector
1/21/2026